



# Commercial Cooking Operations Fire Inspection



## Pre-Inspection Checklist

- Exit Signs
- Emergency Lights
- Unobstructed Exits
- Clean Hood Filters
- No temporary wiring
- ABC Extinguisher in Kitchen
- Type K Extinguisher in Kitchen
- Liquor License (If applicable).
- Semi-Annual inspection report for hood cleaning
- Semi-Annual inspection report for hood suppression system
- Annual inspection reports for fire alarm system (If applicable).
- Annual inspection reports for sprinkler system (if applicable)