



# Commercial Cooking Operations Pre-Fire Inspection Checklist

Sarnia Fire Rescue Services  
240 East Street North  
Sarnia, ON N7T 6X7  
519-332-1122



- Exit Signs**
- Emergency Lights**
- ABC Extinguisher in Kitchen**
- Clean Hood Filters**
- Unobstructed Exits**
- No temporary wiring**
- Type K Extinguisher in Kitchen**
- Liquor License (If applicable).**
- Semi-Annual inspection report for hood cleaning**
- Semi-Annual inspection report for hood suppression system**
- Annual inspection reports for fire alarm system (If applicable).**
- Annual inspection reports for sprinkler system (if applicable).**

