



NOTES:

1. ALL HYDRANTS, PADMOUNTS TRANSFORMERS AND STREET LIGHT POLES ARE TO BE INSTALLED ON THE LOT LINES ONLY AND IN ACCORDANCE WITH FIGURE 1 & 2.
2. DRIVEWAY SHALL BE LOCATED ON THE OPPOSITE SIDE OF THE LOT TO THAT OF A PADMOUNTED TRANSFORMER.
3. WATER SERVICES SHALL BE INSTALLED ON THE CENTRELINE OF SINGLE LOTS AND 1.0M (3.0') TO THE RIGHT AND LEFT OF CENTRELINE FOR SEMI-DETACHED LOTS
4. STORM P.D.C. SHALL BE INSTALLED 2.0M (6.5') RIGHT OF CENTRELINE OF SINGLE LOTS AND 3.0M (10.0') TO THE RIGHT AND LEFT OF CENTRELINE FOR SEMI-DETACHED LOTS
5. SANITARY P.D.C. SHALL BE INSTALLED 3.0M (10') RIGHT OF CENTRELINE OF SINGLE LOTS AND 4.0M (13.0') TO THE RIGHT AND LEFT OF CENTRELINE FOR SEMI-DETACHED LOTS
6. BELL AND HYDRO TO BE INSTALLED IN COMMON TRENCH 0.6M (2.0') FROM EITHER PROPERTY LINES

# 3	UPDATED ASTHETICS	05/14	
# 2	CHANGE STM & SAN.	06/94	
# 1	ADD STORM P.D.C.	12/91	
REV.#	DESCRIPTION	DATE	APP.BY

CITY OF SARNIA

LOT SERVICING

APPROVED BY:

FIELD BOOK# *TOTAL*
STATION

DRAWN BY: DS

SCALE: N.T.S.

DWG. #

CHK'D BY:

DATE: OCT 1997

109-F